

Who Regulates Water Quality?

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (EPA) and Washington State Department of Health (DOH) prescribe regulations which limit the amount of contaminants in water provided by public water systems such as Marblemount.

Other standards for water protection include:

- Assessing drinking water sources;
- Protecting wells;
- Making sure water is treated by qualified operators;
- Ensuring the integrity of water distribution systems;
- Conducting water quality monitoring; and
- Making information available to the public on the quality of their drinking water.

Source of Your Drinking Water

The District obtains water for Marblemount from an aquifer approximately 215 feet below the surface. The well facility automatically pumps water out of the aquifer at 150 gallons per minute to a water storage tank. Within the system, there are 1.9 miles of eight-inch water mains, and 64,000 gallons of distribution storage capacity.

Source Water Protection

To achieve improved protection of public water supply sources and the health of Washington's citizens, the Washington State Department of Health has developed the Source Water Assessment Program (SWAP).

The SWAP program evaluates potential threats to the safety of our water supplies by assessing sources of contamination. The SWAP is designed to give you and your community more information about the source of your drinking water, and any threats to its long-term quality that we can identify and address through a pollution prevention approach.

To learn more about the SWAP, contact the Washington State Department of Health at (360) 236-3149 or visit www.doh.wa.gov/ehp/dw.

Questions?

For more information about your drinking water, please call Skagit PUD at (360) 424-7104. We welcome your comments and suggestions. We also invite you to attend Skagit PUD commission meetings.

The commissioners hold open meetings every Tuesday of the month at 4:30 p.m. in our Aqua Room located at 1415 Freeway Drive, Mount Vernon. You may also visit our Web site at www.SkagitPUD.org.


Important Information Inside About Your Drinking Water



1415 Freeway Drive
P.O. Box 1436
Mount Vernon, WA 98273
tel: (360) 424-7104
www.SkagitPUD.org

Marblemount Drinking Water Quality Report

Public Water System ID No. AA642



Skagit Public Utility District proudly presents its annual water quality report for the Marblemount community to review. In this publication, you will learn where your water comes from, how it is treated, and the results of water quality monitoring conducted in 2008.

We are pleased to inform you that Marblemount's drinking water met or exceeded all state and federal drinking water standards in 2008.

What's in your drinking water ...

The test results summary table below contains actual measurements of water quality parameters that often change from day to day. Test results presented here represent an average of testing conducted throughout the year.

Water Quality Monitoring Results In 2008 For Marblemount Water System

Detected Compounds	Source	EPA Allowable Limits		Marblemount System	Violation
		Ideal Level/Goal MCLG	Maximum Allowable MCL	Range	
Regulated Substances					
Total Coliform Bacteria	Naturally present in environment	0.0%	Can be present in 5% of samples	1 positive sample	Yes*
Lead	Corrosion of household and commercial plumbing	0.0 ppb	Allowable highest 90th percentile is 15 ppb	90th percentile 3 ppb	No
Copper	Corrosion of household and commercial plumbing	0.0 ppm	Allowable highest 90th percentile is 1.3 ppm	90th percentile 0.35 ppm	No
Secondary Regulated Compounds (Substances that cause changes in water's cosmetic or aesthetic qualities: taste, color and odor.)					
Manganese	Naturally present in environment	n/a	0.05 ppm	0.04 ppm	No

*Coliform bacteria are naturally present in the environment and are used as an indicator that other, potentially harmful bacteria, may be present. Total coliform bacteria testing is used to monitor microbial quality in the water distribution system. Skagit PUD collects one routine coliform sample per month from a dedicated site within the Marblemount Water System. In March 2008, laboratory test results indicated that there were coliform bacteria present (no fecal or E. coli bacteria) in the water samples collected. Four repeat samples were submitted and all tested satisfactory. In April, five follow-up samples were tested and again all returned satisfactory results.

Water Quality Definitions

Total Coliforms: A group of non-pathogenic bacteria used in testing water to indicate the presence of pathogenic bacteria. They are naturally present in the environment. If coliforms were found in more samples than allowed, it would be a warning of potential problems.

Chloramines: Compounds used for disinfection; formed by the reaction of chlorine with ammonia. Chloramines extend the disinfecting power of chlorine and reduce the formation of trihalomethanes.

DBP: Disinfection By-Products. Compounds which are formed when water is treated with a disinfectant.

Haloacetic Acids: A disinfection by-product from chlorinating water that contains natural organic matter.

Trihalomethanes: A disinfection by-product from chlorinating water that contains natural organic matter. The most common by-product is chloroform.

MCL: Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG as feasible using the best available treatment technology.

MCLG: Maximum Contaminant Level Goal. The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL: Maximum Residual Disinfectant Level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG: Maximum Residual Disinfectant Level Goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the health benefits of the use of disinfectants to control microbial contaminants.

Turbidity: A measure of the cloudiness of water due to suspended particles.

NTU: Nephelometric Turbidity Units. A unit of measure for turbidity based on the amount of light that is reflected from the water.

ppm: Part per million. One part per million corresponds to one penny in \$10,000 or one minute in two years.

ppb: Part per billion. One part per billion corresponds to one penny in \$10,000,000 or one minute in 2000 years.

TT: Treatment Technique. A required process intended to reduce the level of a contaminant in drinking water.

AL: Action Level. The concentration of a contaminant which, if exceeded, triggers a treatment or other requirement a water system must follow.

Safe Drinking Water: Understanding Potential Sources of Contaminants

DRINKING WATER, INCLUDING BOTTLED WATER, may reasonably be expected to contain at least small amounts of some contaminants. The presence of some contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791) or at www.epa.gov/safewater.

The sources of drinking water (both tap water and bottled water) include lakes, rivers, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants in drinking water sources may include:

- Microbial contaminants, such as viruses and bacteria, which may come from septic systems, wildlife, and farm animals.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, and farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum



production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.



In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as people with cancer undergoing chemotherapy, people who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water.

EPA and Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

