PUD NO. 1 OF SKAGIT COUNTY RANNEY WELL DECOMMISSION JUNE 21, 2019 ADDENDUM NO. 1

To All Planholders and/or Prospective Bidders:

The following changes, additions, and/or deletions are hereby made a part of the project bid documents for the **Ranney Well Decommission** project and shall have the same effect as if set forth therein. Receipt of this Addendum must be acknowledged on your Bidder's Proposal form. Failure to acknowledge receipt of this Addendum will result in your bid proposal being disqualified.

A. Technical Specifications

- 1. SECTION 01010: SUMMARY OF WORK
 - a) In Part 1, Section 1.3A.2.b., removal of above ground portion of the well to 4 feet below the lowest existing grade includes removal of the concrete floor slab that separates the well from the wellhouse.
 - b) In Part 3, Section 3., the Light Weight CDF shall not be dropped more than 6 feet from the end of the conveyance or transporting system; contractor shall use a pumper truck or equivalent for placement.

B. Pre-Bid Meeting Questions

- 1. Is oversight by an electrician needed for the removal of the wiring and other appurtenances?

 No. All wiring and piping in the well and wellhouse has been abandoned or disconnected.
- 2. Does the District have safety requirements above and beyond the Labor and Industries (L&I) Standards for this job?

The contractor must abide by all L&I standards and permitting for this project.

- 3. Can any appurtenances be left in place?
 - No. All appurtenances inside the well must be removed per USACE acceptance of this project. See attachment for photo of appurtenances inside the well.
- 4. Is there water in the well currently?
 - Yes. There is currently water in the well this time, estimated between 10-20 feet from the bottom.

The deadline for receiving bids has not changed and shall continue to be 10:00 AM on Friday, June 28, 2019. This Addendum consists of these 2 pages and 1 pages of attachments, for a total of 3 pages.

Mark Handzlik, P.E. Engineering Manager PUD No. 1 of Skagit County

Attachments: Photo of inside of well

