

**PUD NO. 1 OF SKAGIT COUNTY  
N 18TH ST, E DIVISION ST TO E HIGHLAND AVE, AND  
E FIR ST, N LAVENTURE TO N 30TH ST PROJECT**

**ADDENDUM NO. 2**

Date of Issue: August 17, 2020

**To All Planholders and/or Prospective Bidders:**

**The time and place of bidding remains unchanged** as 10:00 AM, Wednesday, August 19, 2020 via virtual ZOOM Cloud meetings. The web link, meeting ID, and passcode listed below, are also posted on the District's website at [www.SkagitPUD.org](http://www.SkagitPUD.org)

<https://us02web.zoom.us/j/83454269892?pwd=dys0R3dSYzlxjdjdnZG10Q1Z5Y2dxZz09>  
Meeting ID: 834 5426 9892  
Passcode: 859316

Acknowledge receipt of this Addendum in the space provided in the BID FORM. Failure to do so may subject the Bidder to disqualification.

The following changes, additions, and/or deletions are hereby made a part of the project bid documents for the N 18<sup>th</sup> St and E Fir St Project and shall have the same effect as if set forth therein.

**Bid Proposal Forms**

- Addendum #1 Bid Schedule, page Proposal - 4:
  - Strike all references to 8.5% Sales Tax and insert 8.7% (this corrects the appropriate sales tax percentage).

**Answers to Contractor Questions:**

Question	Response
Is there any geotechnical report available for the project or the work site?	No, there is not.
What is the thickness of existing asphalt?	Assume 6-8", or greater
Can entire roadway be closed for during the paving operations?	No.
Are PVC fittings acceptable	No. Fittings shall be ductile iron.

This Addendum #2 consists of this one (1) page.

Mark C. Handzlik, P.E., Engineering Manager  
PUD No.1 of Skagit County

